

LSUE

LOUISIANA STATE UNIVERSITY AT EUNICE

Office of Purchasing • Louisiana State University at Eunice • P. O. Box 1129 • Eunice, LA 70535
Phone: (337) 550-1227 • FAX: (337) 550-1450

BID #469
BASEBALL FIELD LIGHTING

ADDENDUM NO. 1
April 24, 2006

The following changes/additions are to be noted Bid #469, due to be opened at 3:00 p.m., Thursday, April 27, 2006.

1. Specification 16410-SPORTS LIGHTING: Maximum to Minimum Uniformity Ratio shall be 1.5:1 for the infield and 2.0:1 for the outfield.
2. Specification 16410-SPORTS LIGHTING: Grid Spacing shall be 30' x 30'.
3. General: Lighting fixtures shall be mounted a minimum of 70' above grade. Higher mounting heights are acceptable.
4. General: Each pole lighting system shall accept a single 480V, 3-phase input from the electrical distribution system.

COMPANY NAME

SIGNATURE

TITLE

DATE

PHONE AND FAX NOS.

IT IS MANDATORY TO RETURN A SIGNED COPY OF THIS ADDENDUM PRIOR TO BID OPENING. ADDENDUM MAY BE FAXED TO 337-550-1450, BUT BID MUST BE SEALED AND SENT OR DELIVERED TO ADDRESS IN BID SPECIFICATIONS.